

**CARLISLE FIRE DEPARTMENT**

**HOT WORK/OPEN FLAME PERMIT**

NFPA 527 CMR 1.00 Ch. 41, Annex A and NFPA 51B

1. Complete this form and attach a check for \$50.00 **payable to "TOWN OF CARLISLE"**
2. If sending this form electronically, provide contact information below.
3. Leave completed application in the FIRE DEPT. mailbox at Town Hall or mail to the address below with payment.
4. To file electronically: E-Mail application to [FPO@CarlisleFDMA.org](mailto:FPO@CarlisleFDMA.org) and mail payment to Carlisle Fire Dept. P.O. Box 575, Carlisle, MA 01741-0575
5. All work shall be in compliance with *NFPA standards, and State and Local regulations.*

---

**Contact Information**

Property Name: \_\_\_\_\_

Address for work to be done: \_\_\_\_\_

Contractor Name and Lic. #: \_\_\_\_\_

Contractor Address: \_\_\_\_\_

Contractor Phone #: \_\_\_\_\_

E-Mail Address: \_\_\_\_\_

Responsible person onsite during hot work operation: \_\_\_\_\_

Date work to be done \_\_\_ / \_\_\_ / \_\_\_ Start Time \_\_\_ : \_\_\_ Finish Time \_\_\_ : \_\_\_

**FIRE PREVENTION OFFICE**

**978-287-0072**

**[FPO@CarlisleFDMA.org](mailto:FPO@CarlisleFDMA.org)**

**Check List on Back**

## Safety Check List

- 1) Have Extinguisher's available and know how to use.
- 2) Hot Work equipment in good working order.
- 3) Contractor has evidence of financial responsibility, ex. Insurance certificate. 527 CMR A.41.2.1
- 4) Always consider alternatives when possible. 527 CMR A.41.2.2.3(1)
- 5) Be familiar with *NFPA 527 CMR 1.00 Ch. 41, Annex A and NFPA 51B*
- 6) Permit will be issued for a maximum period of one day. 527 CMR A.41.3.4.3
- 7) You can find the complete safety check list in 527 CMR A.41.3.4.1

### **Important Requirements within 35 Ft. of Hot Work 527 CMR 1.00 Ch. 41.3.4.2**

- 8) Flammable liquids, dust, oily deposits removed.
- 9) Floors swept clean and trash removed from a radius of 35 Ft.
- 10) Combustible floors wet down or covered with fire resistive materials.
- 11) Other combustible storage material removed or covered with approved welding pads, blankets or curtains.
- 12) All wall and floor openings covered.
- 13) Duct and conveyors shut down.

### **Requirements for hot work, fire watch and fire monitoring 527 CMR A.41.3.4.1**

- 14) Fire watch is provided during and for a minimum of 30 min. after hot work, including any break activity.
- 15) Fire watch is provided with suitable extinguishers and, where practical, a charged small hose.
- 16) Fire watch is trained in use of equipment and in sounding alarm.
- 17) Fire watch can be required in adjoining areas, above and below.
- 18) All work area's need to be checked 30 minutes after work is completed.